NC/QC/YD-W03/2019-20/WS-C3a

Date: 08-08-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Providing Borewell water pipe lines Water Supply works at ward no.03.}
Ref.: Material testing/QC/19-20,
Report Required for: Assistant Executive Engineer,
Yelahanka New Town Sub Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: M/s KRIDL.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{30}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	11-07-19	08-08-19	28	22500	735	32.67	**32.67**
	002	"	"	"	"	740	32.89	
	003	"	"	"	"	730	32.44	

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರ
ಯಲಹಂಕ ಉಪನಗರ ಉಪವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-106

KIRAN. R
M.E. (Civil-Engg)

For Newzen Consultants Bangalore

Proprietor